

Short Form Classification Report No. 21485H

PRODUCT

Corian® (standard grade)

SPONSOR

DUPONT DE NEMOURS (BELGIUM) BV

PRODUCT DETAILS

- Nominal thickness: 12 ± 0,6 mm
- Nominal density: 1760 kg/m³
- No use of fire retardants
- Valid for all colours (as long as the colour is within the tested ATH percentages)
- ATH percentage: known by the laboratory

FIELD OF APPLICATION

- Substrate: Euro class A2-s1,d0 or better, excluding paper faced gypsum plasterboards, with a minimal thickness of 9 mm and a minimal density of 652,5 kg/m³.
- Fixing: Glued onto the substrate using Fix All High Tack glue of Soudal in an amount of 190 g/m². The glue is applied in dots (all over the surface) and rills (at the edges).
- No Joints

CLASSIFICATION

C-s1,d0

STANDARDS

Test standard: EN ISO 11925-2:2020 & EN 13823:2020

Classification standard: EN 13501-1:2018

SIGNED

APPROVED

For and on behalf of WFRGENT nv

This short form classification report has been drafted according to EGOLF agreement EGA 039:2021 "Application note: clause 7.8 [7.8/1] – Types of reports". Whilst the test data and classification provided within this short form report was obtained in a test conducted fully in accordance with the standards EN ISO 11925-2:2020, EN 13823:2020 & EN 13501-1:2018, the presentation of the results in this short form report may not satisfy the requirements of those standards and EN ISO/IEC 17025:2017. The presentation of the results in this manner is made by agreement with the sponsor and use of the information herein for product assessment, approval or certification purposes will be restricted.

The full classification report No. **21485F** is available at **DUPONT DE NEMOURS (BELGIUM) BV**.

This document is the original version of this report and is written in English. This document may be used only literally and completely for publications. For publications of certain texts, in which this document is mentioned, our permission must be obtained in advance.

The authenticity of the electronic signatures is assured by Belgium Root CA.